

PROFFERED PAPER PP18.3

**Presented at the 2007 Annual Scientific Meeting & Exhibition of
The Australian Society for Microbiology, Adelaide.**

**Seven Years of *Legionella pneumophila* serogroup 1
Cooling Tower Isolations in Tropical Northern Australia.**

Sofroni Eglezos¹, Gordon Gudgeon², Bixing Huang³, Ed Stuttard¹

¹EML Consulting Services QLD, Tennyson, Australia

²COGENT Partners, Brisbane, Australia

³Queensland Health Scientific Services, Coopers Plains, Australia.

Legionella monitoring is an essential tool in performance based microbial control of cooling water systems. Analysis for *Legionella pneumophila* serogroup 1 (*LpnSG1*) was performed on Northern Australian cooling tower water samples by NATA accredited laboratories using AS3896 (1998). A total of 6650 samples were analysed from July 2000 to December 2006 with an overall *LpnSG1* prevalence of 6.11%. Of the positive samples, the mean was 3.0 log CFU/mL, and counts at the 90th, 95th, and 99th percentiles were 3.4, 3.6, and 3.9 log CFU/mL, respectively. Annual prevalence was greatest in 2002 at 11.81%, and least in 2004 at 2.80%. There was a significant relationship ($P < 0.05$) between wet season and *LpnSG1* prevalence and counts, with the hot / humid months presenting with a greater prevalence and higher microbial levels. This study provides valuable data on *LpnSG1* cooling tower prevalence and levels in tropical environments.